

KENDALL COUNTY WELL PERMIT W-4529

Attention Owner:
Confidentiality Privilege Notice
on reverse side of owner's copy.

Texas Department of License and Regulation
Water Well Driller/Pump Installer Program
P.O. Box 12157, Austin, Texas 78711 (512)463-7880 FAX (512)463-8616
Toll free (800)803-9202

This form must be completed
and filed with the department
and owner within 60 days
upon completion of the well.

Email address: water.well@license.state.tx.us

WELL REPORT

Name STEVE BENNETT	Address PO BOX 1934	City BOERNE	State TX	Zip 78006
------------------------------	-------------------------------	-----------------------	--------------------	---------------------

County KENDALL	Physical Address 242 PRADO CROSSING	City BOERNE	State TX	Zip 78006
--------------------------	-----------------------------------------------	-----------------------	--------------------	---------------------

3) Type of Work <input checked="" type="checkbox"/> New Well <input type="checkbox"/> Reconditioning <input type="checkbox"/> Replacement <input type="checkbox"/> Deepening	Lat. _____ Long. _____	Grid # 608-11-5
4) Proposed Use (check) <input type="checkbox"/> Monitor <input type="checkbox"/> Environmental Soil Boring <input checked="" type="checkbox"/> Domestic <input type="checkbox"/> Industrial <input type="checkbox"/> Irrigation <input type="checkbox"/> Injection <input type="checkbox"/> Public Supply <input type="checkbox"/> De-watering <input type="checkbox"/> Testwell <input type="checkbox"/> Rig Supply		5) NT
If Public Supply well, were plans submitted? <input type="checkbox"/> Yes <input type="checkbox"/> No		

6) Drilling Date Started 10/5/03 Completed 10/9/03	Diameter of Hole Dia. (in.) From (ft) To (ft) 8-3/4" 0 560ft	7) Drilling Method (check) <input type="checkbox"/> Driven <input checked="" type="checkbox"/> Air Rotary <input type="checkbox"/> Mud Rotary <input type="checkbox"/> Bored <input type="checkbox"/> Air Hammer <input type="checkbox"/> Cable Tool <input type="checkbox"/> Jetted <input type="checkbox"/> Other _____
------------------------------------------------------------------------	---------------------------------------------------------------------------	------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------

From (ft)	To (ft)	Description and color of formation material
0-1		Topsoil
1-25		Caliche rock
25-133		Gray lime (some shale)
133-145		Light gray-cream lime
145-150		Honeycomb-yellow shaley lime
150-154		Medium gray oily lime
154-157		Yellow honeycomb
157-200		Gray shaley lime (oily)
200-225		Light gray porous lime
225-240		Cream lime
240-270		Tan - gray lime
270-275		Porous cream lime-some water

(Use reverse side of Well Owner's copy, If necessary) (OVER)

8) Borehole Completion Open Hole Straight Wall
 Under-reamed Gravel Packed Other _____
If Gravel Packed give the interval from _____ ft. to _____ ft.

Casing, Blank Pipe, and Well Screen Data

Dia. (in.)	New Or Used	Steel, Plastic, etc. Perf., Slotted, etc Screen Mfg., if commercial	Setting (ft)		Gage Casing Screen
			From	To	
5"	SDR 17	pvc casing	0	278	ft
			280 ft total		

13) Plugged Well plugged within 48 hours
Casing left in well: _____ Cement/Bentonite placed in well: _____

From (ft)	To (ft)	From (ft)	To (ft)	Sacks used

9) Cementing Data
Cementing from **0** ft. to **278** ft. ~~XXXXXX~~ **3yds TOTAL**
ft. to _____ ft. # of sacks used _____
Method Used **8-sk grout**
Cementing By **H.W. SCHWOPE & SONS INC**
Distance to septic system field or other concentrated contamination **100** ft.
Method of verification of above distance _____

14) Type Pump
 Turbine Jet Submersible Cylinder
~~XXXX~~ **HP Weber set @ 541 ft**
Depth to pump bowls, cylinder, jet etc., _____ ft.

10) Surface Completion
 Specified Surface Slab Installed
 Specified Surface Sleeve Installed
 Pitless Adapter Used
 Approved Alternative Procedure Used

15) Water Test
Type test Pump Bailor Jetted Estimated
Yield: **1.2-1.5** gpm with _____ ft. drawdown after _____ hrs.

11) Water Level
Static level **360** ft. below _____ Date _____ / _____ / _____
Artesian Flow _____ gpm. Date _____ / _____ / _____

16) Water Quality
Did you knowingly penetrate a strata which contain undesirable constituents.
 YES NO If yes, did you submit a REPORT OF UNDESIRABLE WATER
Type of water _____ Depth of Strata _____
Was a chemical analysis made Yes No

12) Packers
Type Depth
5" shopmade packer 278 ft
5" rubber packer

Company or individual's Name (type or print) **H.W. SCHWOPE & SONS INC** Lic. No. **1566**

Address **P.O. BOX 364** City **BOERNE** State **TX** Zip **78006**

Signature **John C. Schwope** Signature **Jimmy Cook**

